

水質 計測値

		水質		
日付		濁度(NTU) 管理基準値: 100以下	PH 管理基準値: 7.0~8.3	備考
2016/6/1	水	11.0	7.1	
2016/6/2	木	11.0	7.0	
2016/6/3	金	10.0	7.2	
2016/6/4	土	10.0	7.1	
2016/6/5	日			
2016/6/6	月	10.0	7.1	
2016/6/7	火	11.0	7.0	
2016/6/8	水	10.0	7.2	
2016/6/9	木	21.0	7.4	
2016/6/10	金	15.0	7.3	
2016/6/11	土	13.0	7.0	
2016/6/12	日			
2016/6/13	月	28.0	7.5	
2016/6/14	火	31.0	7.3	
2016/6/15	水	40.0	7.0	
2016/6/16	木	61.0	7.1	
2016/6/17	金	55.0	7.4	
2016/6/18	土	32.0	7.2	
2016/6/19	日			
2016/6/20	月	31.0	7.0	
2016/6/21	火	13.0	7.0	
2016/6/22	水	10.0	7.3	
2016/6/23	木	36.0	7.2	
2016/6/24	金	24.0	7.0	
2016/6/25	土	46.0	7.1	
2016/6/26	日			
2016/6/27	月	10.0	7.2	
2016/6/28	火	12.0	7.0	
2016/6/29	水	11.0	7.0	
2016/6/30	木	10.0	7.1	